



Date Submitted: 6/26/2012

Water Use Efficiency Annual Performance Report - 2011

WS Name: UNDERWOOD

Water System ID# : 90200

WS County: SKAMANIA

Report submitted by: Tom Vance

Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 01/01/2011 To 12/31/2011

Incomplete or missing data for the year? No

If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	66,528,770 gallons
Authorized Consumption (AC) – Annual Volume	31,913,082 gallons
Distribution System Leakage – Annual Volume TP – AC	34,615,688 gallons
Distribution System Leakage – Percent DSL = [(TP – AC) / TP] x 100	52.0 %
3-year annual average	41.3 %

Goal-Setting Information:

Date of Most Recent Public Forum: _____ Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

Goal setting public forum has not been set at this time, plans are in place to complete this in the summer of 2012.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

Leak Detection in 2012 is the priority for this system we have completed leak detection in June of 2012, and plan a second round in August using a consultant for Leak Detection.

Do not mail, fax, or email this report to DOH