



Date Submitted: 6/29/2016

## Water Use Efficiency Annual Performance Report - 2015

WS Name: UNDERWOOD

Water System ID# : 90200

WS County: SKAMANIA

Report submitted by: Tom Vance

### Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not fully metered - Current status of meter installation:

### Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 01/01/2015 To 12/31/2015

Incomplete or missing data for the year? No

If yes, explain:

### Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	52,969,660 gallons
Authorized Consumption (AC) – Annual Volume	37,299,493 gallons
Distribution System Leakage – Annual Volume TP – AC	15,670,167 gallons
Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$	29.6 %
3-year annual average	27.0 %

### Goal-Setting Information:

Date of Most Recent Public Forum: 04/07/2014 Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

### WUE Goals:

Customer Goal (Demand Side):

*Implementation of the proposed WUE measures is anticipated to satisfy the water saving benchmarks outlined in the Water Use Efficiency Goal. Meeting the proposed goal of reducing residential max day demand by 2% will result in water savings of approximately 7,000 gallons per day.*

### Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

*We provided outdoor Watering kits for our customers.*

### Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

*We conducted aggressive leak detection survey.*

**Do not mail, fax, or email this report to DOH**